



## VKF Hagelschutz Nr. 30979

**Inhaber /-in**

Axitec Energy GmbH & Co. KG  
Otto Lilienthal-Strasse 5  
71034 Böblingen  
Germany

**Hersteller /-in**

Axitec Energy GmbH & Co. KG  
71034 Böblingen  
Germany

**Gruppe**

121 - Dach - Photovoltaik Module

**Produkt**

AC-xxxP/72S, AC-xxxP/60S, AC-xxxM/72S, AC-xxxM/60S, AC-xxxPH/144S, AC-xxxPH/120S, AC-xxxMH/144S, AC-xxxMH/120S, AC-xxxP/72V, AC-xxxP/60V, AC-xxxM/72V, AC-xxxM/60V, AC-xxxPH/144V, AC-xxxPH/120V, AC-xxxMH/144V, AC-xxxMH/120V

**Beschreibung**

PV-Modul.  
Frontabdeckung aus gehärtetem Glas (ESG), Stärke = 3,2 mm, in Alu-Rahmen gelagert.  
Die Anerkennung bezieht sich nur auf den solaren Teil, nicht auf eine allfällige Randabdeckung und die Unterkonstruktion.

**Unterlagen**

-: Bestätigung Hersteller '20191113' (13. November 2019)

**VKF Prüfbestimmungen**

A VKF-Beschluss Dichtungsbahnen vom 1.7.2015 (EN 13583)

**Klassifikation  
Beurteilung**

Hagelwiderstand Funktionalität HW 3

**Bemerkungen**

**Gültigkeitsdauer** 31.12.2024  
**Ausstellungsdatum** 03.02.2021  
**Ersetzt Dokument vom** 02.12.2019

Vereinigung Kantonaler Feuerversicherungen

Martin Jordi

Eveline Augsburg

Die Funktionalität ist der minimale Hagelwiderstand von den Bauteilfunktionen:

Lichtdurchlässigkeit	HW --	Mechanik	HW --
Lichtabschirmung	HW --	Wasserdichtheit	HW --